

Modeling of cooling circulating water in cooling towers

© **Vitaliy G. Afanasenko**,*⁺ **Evgeniy V. Boev**, and **Evgeniy A. Nikolaev**

*Equipment of Petrochemical Plants Division. USPTU. Kosmonavtov St., 1. Ufa, 450062.
Bashkortostan Republic. Russia. Phone: +7 (347) 243-11-45. E-mail: awirus@rambler.ru*

*Supervising author; ⁺Corresponding author

Keywords: *heat-mass exchange, water recycling, modeling, irrigation, cooling tower.*

Abstract

One of the key elements of industrial cooling towers is the heat-mass exchange attachment - irrigation. This article presents the results of computer simulation of processes occurring in the amount of sprinkler cooling tower, consisting of vertical corrugated plastic pipe. Based on research to improve the efficiency of heat-mass exchange processes, there are given the recommendations on the layout of blocks regular packing.